





- FIRE ALARM LEGEND**
- FACP** ADDRESSABLE FIRE ALARM CONTROL PANEL
  - FAT** FIRE ALARM RADIO TRANSMITTER, KING FISHER
  - F** MANUAL FIRE ALARM PULL STATION; 48" MOUNTING HEIGHT, U.N.O.
  - S** EMERGENCY SPEAKER / STROBES; 80" WALL MOUNTING HEIGHT, OR CEILING MOUNT, WHITE WITH CLEAR LENS
  - SP** EMERGENCY SPEAKER, WALL OR CEILING MOUNT
  - SD** PHOTOELECTRIC SMOKE DETECTOR, ADDRESSABLE
  - SDT** DUCT MOUNTED SMOKE DETECTOR, ADDRESSABLE
  - ST** SPRINKLER SYSTEM TAMPER SWITCH
  - FS** SPRINKLER SYSTEM FLOW SWITCH
  - AM** ADDRESSABLE MONITOR MODULE
  - ACM** ADDRESSABLE CONTROL MODULE
  - DO** DOOR HOLD OPEN DEVICE
  - FR** FRT ANTENNA
  - MMK** KNOX BOX WITH TAMPER SWITCH
  - W** WEATHERPROOF
  - LH** UNLESS NOTED OTHERWISE ALL AREAS ARE LIGHT HAZARD, 0.10 GPM/ 3,000 SF AND 250 GPM HOSES
  - OH1** ORDINARY HAZARD GROUP 1  
0.15 GPM / 3,000 SF AND 500 GPM HOSES
  - OH2** ORDINARY HAZARD GROUP 2  
0.2 GPM / 3,000 SF AND 500 GPM HOSES
  - REFER TO FP-501 FOR ADDITIONAL NOTES AND DETAILS

**1 FIRE PROTECTION PLAN**  
1/8" = 1'-0"

SEE FP-501 FOR NOTES AND DETAILS



<b>CONSULTANTS:</b>  CIVIL: KENNETH HORNE & ASSOCIATES 7201 NORTH 9TH AVENUE, STE. 6 PENSACOLA, FLORIDA 32504 PH: (850) 471-9005 FX: (850) 471-0093  LANDSCAPE ARCHITECT: CSA GROUP, INC. 6300 PICCADILLY SQUARE DRIVE MOBILE, ALABAMA 36609 PH: (251) 344-4023 FX: (251) 344-4052		<b>ARCHITECT/ENGINEERS:</b>    BES DESIGN/BUILD, LLC 766 Middle St, Fairhope, AL 36532 Phone: 251.990.5778 Fax: 251.990.3716		<b>Drawing Title</b> FIRE PROTECTION PLAN	<b>Project Title</b> CONSTRUCT VA OUTPATIENT CLINIC, PANAMA CITY	<b>Project Number</b> 520-326 <b>Building Number</b> -	<b>Office of Construction and Facilities Management</b> 
<b>Revisions:</b>		<b>Date</b>		<b>Approved: Project Director</b>	<b>Location</b> PANAMA CITY, FLORIDA	<b>Drawing Number</b> FP101	
					<b>Date</b> 9 APRIL 2013	<b>Checked</b> JM	